



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आजादी का  
अमृत महोत्सव

No. F.6/DFS/MS/EH/WZ/2022/ 724

Dated 14/12/2022

To,

The Joint Commissioner of Police,  
Licensing unit, 1<sup>st</sup> Floor,  
Police Station Defense Colony, New Delhi.

Subject: Inspection report for issuance of Fire Safety Certificate in r/o M/s. Kaleva Foods Restaurant located at Ground Floor, GD-28, Pitampura, New Delhi.

Sir,

With reference to the online application received through MHA portal vide ID-202211420177 on the subject cited above. In this connection it is to inform you that the above said premise was inspected by the officer concerned of this department on 06.12.2022 in presence of Sh. Chitranjan (manager), to check the required fire safety arrangements as per laws in the building.

During the course of inspection, it was observed that the restaurant is running at ground floor in a building comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, first aid hose reel, down comer, overhead water storage tank, terrace pump capacity 450 LPM etc. found provided. However, following shortcomings were observed: -

1. Seating arrangement provided in the mezzanine is not sanctioned as per building plan submitted on MHA portal.
2. Alternate staircase for mezzanine floor is not provided.
3. Building plan submitted on MHA portal is not duly signed by owner and architect.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully

(Ajay Garg)

Director

Copy to:

1. The Owner/occupier, M/s. Kaleva Foods Restaurant, Ground Floor, GD-28, Pitampura, New Delhi.
2. The Deputy Health Officer, Keshav puram Zone, North DMC, A-1, Keshav puram, New Delhi.