



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F.6/DFS/MS/EH/WZ/2022/ 726

Dated 14/12/2022

To,

The Joint Commissioner of Police,
Licensing unit, 1st Floor,
Police Station Defense Colony, New Delhi.

Subject: Inspection report for issuance of Fire Safety Certificate in r/o M/s. Miraco Ventures Private Limited located at G-4, First Floor, Pushkar Enclave, Paschim Vihar, New Delhi- 110063.

Sir,

With reference to the online application received through MHA portal vide ID-2022102819474 on the subject cited above. In this connection it is to inform you that the above said restaurant was inspected by the officer concerned of this department on 06.12.2022 in presence of Sh. Rohit Sharma, to check the required fire safety arrangements as per laws in the building.

During the course of inspection, it was observed that the restaurant is running at first floor in a building comprised of basement, stilt, ground plus three upper floors served by single staircase having width 1.5 mts. Fire safety arrangements such as fire extinguishers, first aid hose reel, down comer system, overhead water storage tank, fire pump etc. found provided. However, following shortcomings were observed: -

1. One additional staircase having width 1.5 mts is required.
2. Fire pump found provided but non-functional.
3. Hose reel & down comer system are provided but not functional.
4. Exit signages are not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully

(Atul Garg)
Director

Copy to:

1. The Owner/occupier, M/s. Miraco Ventures Private Limited located at G-4, First Floor, Pushkar Enclave, Paschim Vihar, New Delhi- 110063.
2. The Deputy Health Officer, Keshav puram Zone, North DMC, A-1, Keshav puram, New Delhi.