

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001**

F6/DFS/MS/2022/NDZ/ 3025

Dated: 06.12.2022

To,

The Executive Engineer,
Delhi High Court Civil Division (M-431) PWD,
Gate No-6, Jawahar Lal Nehru Stadium,
New Delhi -03.

**Sub:- Regarding compliance of shortcomings in r/o S- block, at Delhi High Court,
Zakir Hussain Marg, New Delhi.**

Sir,

This has reference to your letter no. 34 (S-Block) EE/Delhi High Court/PWD/812 dated 14.11.2022, on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 25/11/22 in the presence of Sh. Manoj Bhaskar, AE(C) & Sh. M.C Gupta, EE and the following shortcomings are still not complied:

1. Electric shafts/openings are not sealed properly.
2. Pressurization of staircase, lift lobby & 8th floor is not provided.

In view above shortcomings, you are once again requested to rectify the shortcomings completely and inform to this department for further consideration in the matter.

Yours faithfully

(Atul Garg)

DIRECTOR

Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra New Delhi.
2. The Chief Engineer (E), PWD, MSO building, New Delhi.
3. The Registrar (General Admn.), High Court, New Delhi.