

## **GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F.6/DFS/MS/Banquet/WZ/2022/ 235

Dated: - 12/12/2022

To,

The Dy. Health Officer, Narela Zone, Municipal Corporation of Delhi, New Delhi.

Sub:- <u>Renewal of Fire Safety Certificate in respect of M/s. Le Paradise Banquet Hall, Khasra No.</u> 523/2 (0-09), 528/2 (1-0), Main Rohtak Road Mundka, New Delhi.

Sir,

This has reference to your online application received through MHA portal vide ID-2022101319005, on the subject cited above. In this connection it is to inform you that the above said assembly building has been inspected by the officer concerned of this department on 06.12.2022 in presence of Sh. Deepak (manager), to check the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that the banquet hall building is comprised of basement, ground and two upper floors. Fire safety arrangements such as fire extinguishers, hose reel, down comer, detection system, sprinkler system in basement floor, MOEFA, fire pump etc. found provided. However, following shortcomings have been observed:

- 1. Terrace pump found removed.
- 2. Fire electric pump and diesel pump are provided but not functional.
- 3. Pressurization system in staircase, lift & lift lobbies found removed.
- 4. Fire check door found removed.
- 5. Sprinkler system, down comer & hose reel hose are provided but not functional.
- 6. MOEFA & Detection system are provided but not functional.
- 7. Smoke management system in basement floor found provided but not functional.
- 8. Exit signages found removed at some places.

In view of above shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

(Dharampal Bhardwaj) Dy. Chief Fire Officer (West Zone)

Copy to:-

1. Sh. Sanjay Bansal, M/s. Le Paradise Banquet Hall, Khasra No. 523/2 (0-09), 528/2 (1-0), Main Rohtak Road Mundka, New Delhi.