

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2022/SZ/ 717
To

Dated 9 / 12 / 2022

The Dy. Health Officer, South Delhi,
Public Health Department, MCD,
Aurobindo Marg, Green Park,
New Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s NOSTALGIA BLUES BAR AND GRILL (A Unit of Bonus Bucks Hospitality Pvt Ltd) at M-25, FF & SF, Greater Kailash-1, New Delhi 110048

Sir,

This has reference with MHA Portal ID 2022090717198 dated 07/09/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department in the presence of Mr. Jitender Kumar on 29.11.2022 to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. There are two staircases having width of 1.0 mtr & 1.0 mtr. The minimum widths of two staircases are required 1.50 mtr each as per UBBL-2016.
2. There are two doors having width of 1.0 mtr each against the required width of 1.50 mtr each respectively.
3. One Fire fighting electric pump capacity 2280 LPM with 70m head, one standby fire pump of similar capacity & head and one jockey pump of 180 LPM with head not provided.
4. The underground storage tank of 1,00,000 ltrs capacity for firefighting not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR