

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/ 716

Dated:- 9.11.2022

To

The Manager
M/S Doon Caterers,
5198, Balkishan Gali, Basant Road,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Doon Caterers, 5198, Balkishan Gali, Basant Road, Pahar Ganj, New Delhi. ID NO. 2022100418638 dated 04.10.22

Sir,

This has reference to online ID No. 2022100418638 dated 04.10.22, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned of this department on 29/11/2022 in the presence of Sh. Ravinder and following shortcomings were observed:-

1. 06 meters access road to building is not provided.
2. 01 staircase of 1.0 meter is provided against the requirements of 02 Staircase of 1.5m each.
3. 02 exits of 1.5 meter each are not provided.
4. First aid hose reel provided but found non functional.
5. MOEFA is not provided.
6. The hydrant system is not provided.
7. Terrace pump of 450 LPM is not provided.
8. Overhead fire water tank of 1,000 liter is provided against the requirements of 20,000liter capacity.
9. The location of restaurant is not marked on the building plan as uploaded on the portal and is not signed by owner /occupier himself also.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.