



7.10  
भारतीय  
संघीय प्रशासन  
210

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/WZ/EH/2022/ 730

Dated: 15/12/2022

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in)

Sub: - Inspection report in r/o M/s. Tata Starbucks Pvt. Ltd. (A unit of Tata Alliance),  
CS-003, Ground Floor, R Cube Monad, Rajouri Garden, New Delhi- 110027.

Sir,


This is in reference to the online application received through MHA portal vide 2022102719455 dated 27/10/2022, regarding issuance of Fire Safety Certificate in respect of aforesaid restaurant/ Coffee House. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 05/12/2022 in the presence Sh. Rahul (Shift Manager) to check the fire safety arrangements provided in the building.

During the course of inspection, it was observed that the said restaurant/ Coffee House is running at Ground floor of R Cube Monad Mall Multi Level parking with Commercial development at Rajouri garden New Delhi in a building comprised of 03 basements, ground + 05 upper floors was issued vide letter No. F.6/DFS/MS/WZ/2021/47 dated 22/01/2021. Fire safety arrangements of the restaurant are interlinked with the Mall. However, following shortcoming was observed: -

1. Only one exit of 1.5 mts is provided against requirement of 2 X 1.50 mts. each.
2. Exit signages are not provided.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,


  
(Anil Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Owner/ Occupier M/s. Tata Starbucks Pvt. Ltd. (A unit of Tata Alliance),  
CS-003, Ground Floor, R Cube Monad, Rajouri Garden, New Delhi- 110027.

Online application ID No:- 2022102719455 dated 27/10/2022

2. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi-110027.

  
13/12/2022