

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/SZ/2022/ 3168

Dated: 21/12/2022

To,
The President
Shree Ganesh CGHS Ltd
Plot no - 12 B, Sector - 7, Dwarka,
New Delhi - 110075

Subject: Grant of Fire Safety Certificate in r/o Shree Ganesh CGHS Ltd located at Plot no - 12 B, Sector - 7, Dwarka, New Delhi - 110075.

Sir,

Please refer to your Email dated 08/10/2022 on the subject mentioned above. In this connection it is to inform you that the premise was re inspected by the officer concerned from this department on 18/10/2022 in the presence of Mr.Parmod (Manager) for fire safety point of view.

During the course of inspection following shortcomings have been observed

1. Internal road around the building found encroached / blocked.
2. Hose boxes are not equipped with hoses & branches at some places.
3. Exit signage found removed at some places.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Abul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas sadan, INA, New Delhi