



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No: F.6/DFS/MS/School/WZ/2022/ 743

Dated: 12/12/2022

To

The Principal, Hansraj Model School, Road No. 73, Punjabi Bagh, New Delhi- 110026.

Sub.:- Regarding renewal of Fire Safety Certificate in r/o Hans Raj Model, Road No. 73, Punjabi Bagh, New Delhi.

Sir.

This is in reference to the e-mail dated 05.11.2022 received vide IDinfo@hansrajmodelschool.org on the subject cited above. In this connection, it is to inform you that the school building was inspected by the officer concerned of this department in the presence of Sh. on 06.12.2022 to check the status of the fire safety arrangements already provided in the school building.

During the course of inspection, it was observed that the school complex is having three blocks, Main Block & Yoga Block, Auditorium Block & Primary Block. Main Block & Yoga Block is comprised of basement, ground plus three upper floors, Auditorium Block is comprised of basement & ground floor only, Primary Block is comprised of ground plus two upper floors. Fire safety arrangements such as fire check door, fire extinguishers, first aid hose reel, MOEFA, sprinkler system in basement floor, down comer, terrace pump etc. found provided. However, following shortcomings were observed: -

- Alternate staircase/exit in third floor found removed/block/sealed.
- Fire pumps are provided but not in auto mode.
- 3. Hose reel hose provided but not functional.
- 4. Exit signages found removed at some places.
- 5. Exit gates in Auditorium are in the same direction.

In view of the above, fire safety certificate cannot be renewed at this stage. You are advised to rectify the above mentioned shortcomings under intimation to this department.

Yours faithfully

(Dharampal Bhardwaj) Dy. Chief Fire Officer

West Zone

1. The Directorate of Education, GNCT of Delhi, Old Secretariat, Delhi- 1100