

C-41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2022/WZ/ 750

Dated: 19/12/2022

To,

The Principal,  
Kendriya Vidyalaya,  
Sec. A-5, Pocket-11,  
Narela, Delhi-40.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Kendriya Vidyalaya, Sec. A-5, Pocket-11, Narela, Delhi-40.

Sir,

This has reference to your letter no. 06/K.V. Narela/2022-23 dated 15.11.2022 received via outdoor diary no. 8411 dated 24.11.2022 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 06.12.2022 to see the compliance of the requisite fire safety measures. Sh. Munna Lal (Principal) was present at the time of inspection.

Your request of renewal of FSC is rejected as the following shortcomings were observed:-

1. Fire extinguishers provided but not functional.
2. First aid Hose Reel provided but not functional.
3. Terrace pump provided but not functional.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully,

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

*[Handwritten Signature]*

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secret. Delhi -54.