

L-56

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2022/ 1025

Dated: 21/12/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/S Neha Guest House** located at **3934, Urdu Bazar, Jama Masjid, Delhi -06.**


Sir,

This has reference to online application I.D. no. 2022111920430 dated 19.11.2022 on the subject cited above. It is to inform you that the guest house was inspected by the officer concerned of this department on 08.12.2022 in the presence of Manager and it was observed that building is comprised of Basement + Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire extinguishers found non functional.
2. CO detectors with panel and alarm not provided required as per gazette notification dated 27.05.2019.
3. Fire pump not in auto start mode.
4. Exit signages are not provided.
5. Drawing provided is not matching with actual site, hence as built drawings to be uploaded on MHA portal.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service
Tel: 011-23412222

Copy to:-

The Manager, M/S Neha Guest House at 3934, Urdu Bazar, Jama Masjid, Delhi -06.

o/c
20/12