



75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

NO. F.6/DFS/MS/School/2022/NDZ/ 751

Dated: 20/12/2022

To,

The Principal,  
Spring Bales Public Sr. Sec. School  
7-8, New Gobind Pura, Bhagat Singh Road,  
Delhi-110051

**Subject:- Regarding Renewal of Fire Certificate in r/o Spring Bales Public Sr. Sec. School located at 7-8, New Gobind Pura, Bhagat Singh Road, Delhi-110051.**

Sir,

With reference to your letter No. nil dated 09/11/2022 on the subject cited above, it is informed that, the officer concerned of this department has carried out the inspection of the above mentioned premises from fire safety point of view in presence of Dr. Santosh Dixit on dated 01/12/2022 and observed that the school building is comprised of ground plus three upper floors and 3<sup>rd</sup> floor have been erected without approval of this department. Earlier NOC was issued for the ground plus two upper floors only. This is clear case of addition/alteration. The following information/documents pertaining to the premises/building are required:-

1. Sanctioned/Completion plans on the scale of 1:100 having details of height/covered area, year of construction/conversion of occupancy duly marked with fire and life safety arrangements as stipulated under Rule 33 of Delhi Fire Service Act of Rules 2010.

In view to the above, the premises can not be considered for issuance of renewal Fire Safety Certificate at his stage. Therefore, you are requested to provide above mentioned information/documents at the earliest for further consideration.

Yours Faithfully,

(Atul Garg)  
Director

Delhi Fire Service

ok