

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2022/SZ/ 738
To

Dated: 21.11.2022

The Dy. Health Officer, (South Zone)
Public Health Department, MCD,
Green Park, Zone, New Delhi 110016

Sub: Regarding issuance of FSC in r/o M/s WENDYS (A unit of Sierra Nevada Restaurants P Ltd)
Plot No H1A, GF & FF, Zorawar Tower Kalkaji New Delhi-110019.

Sir,

This has reference to with **MHA Portal ID 2022111720309 dated 18/11/2022** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02.12.2022 in the presence of Mr. Vineet (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two Staircases having widths of 1.25 mtr each against the required width of 1.50 mtr each as per UBBL-2016.
2. First Aid Hose Reel not provided.
3. The MOEFA system is not provided.
4. The Internal Hydrant not provided.
5. Terrace level Fire Pump capacity of 450 LPM not provided.
6. Overhead tank capacity 20,000 ltrs not provided.
7. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

1. M/s WENDYS (A unit of Sierra Nevada Restaurants P Ltd) Plot No H1A, GF & FF, Zorawar Tower Kalkaji New Delhi-110019.