

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2022/305

Dated: 26/12/2022

To,

The President,
The Shakuntalam CGHS LTD
Plot No-16 Sector- 10, Sector - 4,
Dwarka, New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Shakuntalam CGHS LTD. Located at Plot No-16 Sector- 10, Sector - 4, Dwarka, New Delhi.

Sir,

Please refer to your Email dated-24/11/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 16/12/2022 in the presence of Sh. Amit Sardana (Secretary) for fire safety point of view.

The following shortcoming was observed during the time of inspection:-

1. The internal road around the building has been encroached / blocked. The internal road must be free from any obstruction.
2. All the stairs must be clear from any obstruction and must not be locked at terrace level.
3. Only one fire extinguishers of ABC type 5Kg capacity is found provided against required two fire Extinguishers at each floor.
4. Yard hydrants found removed.
5. Hose reel hose & Hydrant system found non functional
6. MOEFA found nonfunctional.
7. Terrace pump found nonfunctional.
8. Exit signage's found removed at some places.
9. Communication system in lift car found nonfunctional.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Gang)
Director,
Delhi Fire Service.

Copy to; - The Chairman, DDA, Vikas Sadan, INA, Delhi-110023

100k
22/12/22