

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2022/3213

Dated: 27/12/2022

To,

The Authorized Signatory,  
City Max Hotels India Pvt Ltd,  
3<sup>rd</sup> floor, 77 Town Centre,  
Off Hal Airport Road, P.O Bangalore

**Subject: Renewal of Fire Safety Certificate in r/o Video Game Parlour Located at 4th floor Vegas Mall Plot No 6, Sector 14, Dwarka, New Delhi.**

Sir,

Please refer to Form J & DFS Outdoor diary No. 6539 dated 10-10-2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 15/12/2022 in presence of Mr. Chaten Sahani (Manager) for fire safety point of view.

During inspection the followings shortcomings were observed.

1. The exits doors provided at staircases are found partially blocked.
2. The lift lobby found being used as storage of cleaning material.
3. One hydrant & hose reel was found blocked.
4. The combustible material used in decoration/ partition must be treated with fire retardant paint.
5. Loose wiring/ open wiring seen during inspection.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Choudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.
2. The Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
3. The Manager Video Game Parlour Located at 4th floor Vegas Mall Plot No 6, Sector 14, Dwarka, New Delhi

Handwritten initials and date: H/O/S 27/12/22