

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/3212

Dated: 27/12/2022

To,

Sh. Ajay Khatri
DGM – Fire & Safety,
Indraprastha Gas Limited
New Delhi

Subject: Renewal of Fire Safety Certificate in respect of Hybrid CNG filling station outside DTC Depot, Sector-8, Dwarka, New Delhi.

Sir,

Please refer to your letter No. IGL/F&S/2022/15/78/1, dated 24/11/2022 on the subject mentioned above. In this connection it is to inform you that the above said premise was re - inspected by the officer concerned of this department on 20/12/2022 in the presence of Sh. Sunil Sharma (Technician).

During course of inspection the following shortcomings were observed:

1. Fire water mist cum foam trolley found non functional.
2. MOEFA found non functional.
3. During the visit it is observed that no one on duty is capable to operate CO2 Flooding/ DCP flooding/ Water mist foam Trolley. Trained staff must be available to operate the systems.
4. Dully fill form J & K

You are requested to comply above mentioned shortcomings under intimation to this department.

Yours faithfully,

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to-

1. Sh. Alok Sharma, Vice President-Fire & Safety IGL Bhawan, Plot No-4, Community Center, R K Puram Sec-9, New Delhi.
2. Shri Arun Kumar Singh, Chairman, Fire & Safety IGL Bhawan, Plot No-4, Community Center, R K Puram Sec-9, New Delhi.
3. The Manager Hybrid CNG filling station outside DTC Depot, Sector-8, Dwarka, New Delhi.