

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2022/3210

DATED: 26 / 12 / 2022

To,

The President, <daffodilsdwarka@yahoo.in>
The Daffodils CGHS Ltd.
Plot No 36, Sector – 6, Dwarka, New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o The Daffodils CGHS Ltd. Located at Plot No 36, Sector – 6, Dwarka, New Delhi.

Sir,

This is in reference to your letter No. Daff/Fire Safety/2022/01 dated 19/11/2022 on the subject cited above. In this connection it is to inform to you that the above said premises was re - inspected by the officer concerned of this department on 19/12/2022 in the presence of Dr. HP Malik (Vice President) & Dr. U Nerula (President)

During the course of inspection followings shortcoming have been observed:-

1. The internal road around the building has been encroached / blocked.
2. Stairs are found partially blocked.
3. Hoses and Branches found missing at some floors/ places.
4. Hose reel hoses/ Nozzles were found missing at some floors.
5. Hydrant coupling found missing at some floors/ places.
6. Communication system found provided in the lifts but found nonfunctional.
7. Fire man ground switch for lift car found provided but nonfunctional.
8. During the inspection one hydrant and hose reel was operated, leakage was noted from nozzle, branch and fittings. All the branches, Hoses, fittings must be ISI marked.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Anil Garg)
(Director)

Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.

