GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 32 32

Dated: 28/12/2022

To.

The Authorized Signatory, Mother Dairy Fruit & Vegetable, Phase-1, Mangolpuri Ind. Area, Delhi-110083.

Sub: Issue of FSC in r/o Mother Dairy Fruit & Vegetable Phase-1, Mangolpuri Ind. Area, Delhi-110083.

Sir,

This is in reference to your letter No. nil dated 21.09.2022 received through outdoor diary no. 5963 dated 22.09.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **25.11.2022**, in presence of **Sh. Deepak Verma** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

- 1. Alternate staircase of 1.25 mtr is not provided in basement.
- 2. Smoke ventilation not provided in central store.
- Detection system not provided in central store.
- Sprinkler system not provided in central store & Service block.
- 5. Terrace tank in not dedicated & valve is closed in admin block.
- Ventilation is not provided in basement in admin block & central block.
- 7. Single staircase found in basement in admin block.
- 8. Hose reel / internal hydrants are not provided as DS 3844.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under: http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Dhrampal Bhardwaj) Dy.Chief Fire Officer Tel;-01123414250

ofe