

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2022/NDZL3229

Dated 25 / 12/2022

To,

The Executive Engineer,
CPWD, Safdarjung Hospital Electrical Division,
New Delhi – 110002.

**Sub:- Regarding renewal of FSC in r/o Manak Bhawan 9, Bahadur Shah Zafar Marg,
New Delhi – 110002.**

Sir,

This has reference to your letter No 25(3)/DB/SHED/2022-2023/105 dated 19/10/22 on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 14/12/2022 in the presence of Sh. Anuj, Dy. Director, CPWD. The following shortcomings are still not complied: -

1. Electric shaft/openings are not sealed properly.
2. Smoke management system in basement found nonfunctional.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to

1. Sh A.K.Das , Head, PMWD, BIS Manak Bhawan , 09, Bahadur Shah Zafar Marg, New Delhi.