

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2022/3234

Dated: 28/12/2022

To

Smt. Moumita Biswas,
General Secretary,
Girls Hostel YWCA,
Ashoka Road, New Delhi.

Sub:- Regarding inspection of building from fire safety point of view in r/o Girls Hostel YWCA, Ashoka Road, New Delhi..


Sir,

This has a reference to your letter no. Y/CHWW/2022-23/003 dated 28/11/22 on the subject cited above. In this connection, it is to inform you that the site was inspected by the officers concerned of this department on 21/11/22 in the presence of Mr. Gabriel and the following shortcomings were observed:-

1. MOEFA found nonfunctional.
2. Hydrant system, yard hydrant and hose reel provided but found nonfunctional.
3. Fire Pump found nonfunctional.
4. Overhead tank found empty.

Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,


28/12/22
(S.K.Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.