

C 13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2021/ 674

Dated: 22/12/2021

To,

The Principal,
B. R. Tyagi Sr. Sec. School,
Budh Vihar, Phase-II, Sector-24,
Rohini, Delhi-86.

Sub: Issue of FSC in r/o B. R. Tyagi Sr. Sec. School, Budh Vihar, Phase-II, Sector-24, Rohini, Delhi-86 .

Sir,


Kindly reference to online e-mail dated 21.10.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **10.12.2021**, in presence of **Mr. B. Laksham (Vice Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 450 LPM found removed.
2. 4,000 liters over head water capacity tank provided against the required capacity of 10,000 liters

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

oll
My