

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/NDZ/686

Dated: 28/12/2021

To,
The Principal,
Bharat National Public School,
54, Mahila Colony, Gandhi Nagar,
Delhi-110031

Subject:- Application for Renewal of Fire Safety Certificate.

Sir,

With reference to your email ID bnpsmahilacolony@gmail.com dated 17/11/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Shanta on dated 21/12/2021. The school building comprises of ground plus one upper floor. During the course of inspection following observations were made:-

1. Staircase of width 1.50 meter failing which an additional staircase of 0.75 meter width is required.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,


27/12/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Director of Education, EDMC,
419, Udyog Sadan, Patparganj Industrial Area,
Delhi-110092