

C-27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2021/SZ/ 693

Dated: 31/12/2021

To,
The Magager,
B.V.M Public School,
Ajay Park, Naya Bazar, Najafgarh, New Delhi-43.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o B.V.M Public School, Ajay Park, Naya Bazar, Najafgarh, New Delhi-43.

Sir,

Please refer to your letter No. Nil Dated 03/12/2021 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Praveen Sharma (Principal) was present and it was observed that the building is comprised of ground plus two upper floors and have following shortcomings:-

1. Door size of the class rooms at second floor 1.0 m provided in place of 1.20 m.
2. First aid hose reel provided but not functional.
3. Fire pumps having 450 lpm output 40 m head provided but not functional.
4. Exits signages are not sufficient.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054
(with a request to take further action as school does not have fire NOC)