

e19



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 692  
To

Dated: 30.12.2021

The Principal,  
DAV Public School,  
Sector-B Pkt-1, Vasant Kunj,  
New Delhi-110070

Sub: Issuance of NOC in r/o DAV Public School, at Sector-B Pkt-1, Vasant Kunj, New Delhi-110070

Sir,

This has reference to Gmail dated 14-12-2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.12.2021 in the presence of Mr. Bikram Ji to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The Gate width is 04 mtr against the required width of 05 mtr.
2. First aid hose reel not functional & Nozzle missing at some places.
3. Sprinkler testing valve found removed in the basement.
4. Terrace level Fire Pump capacity of 450 LPM not working.
5. Exit signage found removed in some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

**(SUNIL CHAWDHARY)**  
**DY. CHIEF FIRE OFFICER (SZ)**

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054