

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2021/NDZ/ 680

Dated: 27/12/2021

To,

The Principal,
EDMC Primary School,
Sabhapur Gujran-II, Karawal Nagar,
Delhi-110094

Subject:- Regarding inspection of schools for fire NOC.

Sir,


With reference to your email ID eee2shahnorthzone@gmail.com. dated 23/11/2021 on the subject cited above, it is informed that officer concerned of this department visited the school building in the presence of Sh. Ramesh Kr. Morya, Principal & Sh. Gajender Singh, J.E. (Electric), Shahdara North Zone on dated 04/12/2021 and observed that the shortcomings issued vide letter No. F.6/DFS/MS/School/2021/NDZ/611 dated 18/11/2021 have not been complied as yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours faithfully,


23/12/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

1. The Director of Education, EDMC,
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi-110092
2. The Ex. Engr. (Elect.)-II,
Shahdara (North) Zone,
EDMC, Office of Executive Engineer (Elect.)-II,
MCD Zonal Office Building, Keshav Chowk,
G.T. Road, Near Shyam Lal College,

c-20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2021/NDZ/611

Dated 18/11/2021

To,
The Principal,
EDMC Primary School,
Sabhapur Gujran, Karawal Nagar,
Delhi 110094

Sub:- Regarding Issuance Fire Safety Certificate in r/o E.D.M.C Primary school at Sabhapur gujran, Karawal Nagar, Delhi 110094.

Sir,

With reference to your email no.nil dated 06/10/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Dharmendra (Incharge) of the School. During the course of inspection it was observed that the following points / shortcomings were noticed in the building comprised of ground plus three upper floors.

1. The Width of the staircase 1.50 meters wide are not provided

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92