

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2021/ 1031

Dated:-23/12/2021

To,

The Manager,
Hotel Dakha International,974/01,
975/01 & 976/01, Arya Samaj Road,
Karol Bagh, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hotel Dakha International,974/01,
975/01 & 976/01, Arya Samaj Road, Karol Bagh, New Delhi. ID no. 2021111226218
dated 19/11/2021.

Sir,

This has reference to ID No. 2021111226218 dated 19/11/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 16/12/2021 in the presence of Sh. Harish and following shortcomings were observed: -

1. Fire Check Doors of 01 hr. fire rating on the staircase are not provided as per Gazette Notification dated 27.05.2019.
2. Smoke Management system is not provided as per Gazette Notification dated 27.05.2019.
3. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.
4. Affidavit not to use any floor above third floor is also not submitted.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


22/12/21

(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.