

C-21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2021/SZ/1029

Dated: 23/12/2021

To

The Addl. Commissioner of Police (Lic.),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Issuance of NOC in r/o M/s Hotel Paradise International at Plot No A-272, NH-8,
Mahipalpur New Delhi 110037

Sir,

This is in reference with MHA Portal ID 2021102925513 Dated 29/10/2021 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 06/12/2021 in the presence of Ms. Afrin of the Guest House. During the inspection, it was observed that the Guest House is running in Basement, Ground plus Three Upper Floors. During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check door not provided in the building as per clause 7.31 of UBBL-2016.
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

or

Copy to:-

1. M/s Hotel Paradise International at Plot No A-272, NH-8, Mahipalpur New Delhi 110037