

CG

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/WZ/2021/ 669

Dated: - 22/12/2021

To,

The Incharge,  
M.C. Primary Boys School (ID-1556128),  
Ranholla (II), New Delhi- 110041.

Sub.: Regarding renewal of Fire Safety Certificate in r/o M.C. Primary Boys School (ID-1556128), Ranholla (II), New Delhi- 110041.

Sir,

Please refer to your letter No. nil dated 29.10.2021 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Mrs. Saroj, Incharge (1<sup>st</sup> Shift) on 06.12.2021 to check the functionality of the existing fire safety arrangements in the school building.

During inspection, it has been observed that the said school building is comprised of ground and first floor only. Fire safety arrangements such as fire extinguishers, exit signages etc. found provided in the school building. However, the following shortcomings were observed:-

1. Width of main gate is less than required width of 4.5 mts.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer

Copy to: -

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.

-for information please