

G-22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No.F6/DFS/MS/School/2021/SZ/ 694

Dated 31/12/2021

To,


The Manager,
Mata Kasturi Devi Sr. Sec. Public School,
Gopal Nagar, Najafgarh, New Delhi-110043.

Subject: - Regarding issue of FSC from fire safety point of view in r/o Mata Kasturi Devi Sr. Sec. Public School, Gopal Nagar, Najafgarh, New Delhi-110043.

Sir,

This has reference to your letter no.nil dated 13/12/2021 on the subject captioned above. In this connection, it is to inform you that the above mentioned premises was inspected by the officer concerned of this department on 17/12/2021 in the presence of Sh. Kulbhushan (Manager) to verify the compliance of shortcoming already communicated by this department vide letter no. F6/DFS/MS/2021/SZ/128 dated 04/03/2021 has not been complied. The management will be held responsible for any untoward incident for the period if compliance is not made.

Yours faithfully


(Sunil Chawdhary)
Dy.Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

(With a request to take further action as school does not have fire NOC)

C-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2021/SZ /128

Dated: 04/03/2021

To,

The Principal,
Mata Kasturi Devi Sr. Sec. Public School,
Gopal Nagar, Najafgarh, New Delhi-110043.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Mata Kasturi Devi Sr. Sec. Public School, Gopal Nagar, Najafgarh, New Delhi-110043.

Sir/Madam,

This has reference to your Letter No. Nil dated 23/02/2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 19/02/2021 in presence of Sh. Kulbhushan Singh (Manager).


During the course of inspection it was observed that school building comprised of ground floor plus two upper floors was issued FSC by this department vide letter no. F.6/DFS/MS/School/2016/SZ/992 dated 09.06.2016.

The following shortcomings were observed:-

1. An additional staircase having width of 1.0 m provided in place of required 1.35 m from ground floor to terrace.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer



Copy to:-

Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054