

G-15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/2021/ 677

Dated: 22.12.2021

To

The Principal,
Rajkiya Pratibha Vikas Vidyalaya,
Plot No. 1, Link Road, Karol Bagh, Jhandewalan,
New Delhi.

Sub: Regarding Renewal of FSC in r/o Rajkiya Pratibha Vikas Vidyalaya Plot No. 1, Link Road, Karol Bagh, Jhandewalan, New Delhi.

Sir,

This has reference to your letter No. RPVV/LKRB/2021/421 dated 01.12.21 on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 16.12.2021 in the presence of Principal and the following shortcomings were observed.

1. Fire extinguishers found due for refilling
2. Hose reel found nonfunctional
3. Fire pump found nonfunctional.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit .

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.