

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 679

Dated: 22/ 12/ 2021

To

The Principal,  
Sarvodaya Kanya Vidyalaya,  
Madanpur Khadar,  
New Delhi 110076

Sub: Issue of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya, Madanpur Khadar, New Delhi 110076 (ID 1925062)

Sir,

This is in reference to with Gmail dated 11-11-2021. received in this department on the subject cited above. The premise was inspected by the officer concerned of this department in the presence of Mr. Devi Singh (Estate Manager) on dated 10-12-2021 to verify the fire safety measures installed in the building. During the course of inspection, the following shortcoming observed were noticed:-

1. Hose reel hose provided but not on working.
2. Terrace level Fire Pump capacity of 450 LPM provided but not in working.
3. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054