

DPA

C 28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2021/ 663

Dated: 21 /12/2021

To,

Smt. Sushma Gupta (Principal), <mcpsrajnagar2@gmail.com>
S.D.M.C Pratibha Boys / Girls School
Raj Nagar, Palam Colony,
New Delhi – 110077.

Subject: Renewal of Fire Safety Certificate in r/o S.D.M.C Pratibha Boys / Girls School
Located at Raj Nagar, Palam Colony, New Delhi – 110077

Sir,

Please refer to your Email dated 24/11/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 07/12/2021 for fire safety point of view.


The following shortcoming was observed during the time of inspection:-

1. Hose reel hoses found damaged/ removed.
2. Terrace pump found nonfunctional.
3. Over head water tank of 10,000 ltr capacity found damaged.
4. Exit Signage found removed.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.


In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi – 110054


12/12/21