



e 57

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2021/ 675

Dated: 22/12/2021

To,

The Principal,
Shivani Convent School,
266, Gali No.10, Samaypur,
Delhi-110042.

Sub: Issue of FSC in r/o Shivani Convent School, 266, Gali No.10, Samaypur, Delhi-42.

Sir,

Kindly reference to online e-mail dated 24.09.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 30.11.2021, in presence of **Sh. Beer Singh Yadav (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Internal hydrants not functional.
2. Hose reel is provided but not in working condition at the time of inspection.
3. Terrace pump of 450 lpm is found removed at the time of inspection.
4. 1,000 ltrs Over Head water captive tank provided against the required capacity of 5,000 ltrs.
5. The required exit signages are found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

21/12/2021
ole
Be