

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.

26/DAS/ms/school/2021/664

Dated: 21/12/2021

To,

Authorized Signatory,
 St. Joan's Convent School,
 Lodhi Road Complex, New Delhi-110003.

**Subject: Inspection report of St. Joan's Convent School located at Lodhi Road Complex,
 New Delhi-110003.**

Sir,

Please refer to your letter received through email ID-stjoansconvent@gmail.com dated 25/11/2021 on the subject noted above, in this connection it is to inform you that the said premises was visited by the officer concerned of this department on 08/12/2021 in the presence of Smt. Indu Jain (Principal) and observed that building comprised of Basement, Ground & 1st Floor only. Fire safety arrangements such as Fire Extinguishers, Hose Reel Hose, Fire Pump & Over Head Tank were found provided.

The following shortcoming was observed during the time of inspection:-

1. Fire pump provided but found nonfunctional.
2. Sprinkler system provided but found nonfunctional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (S.Z.)

Copy to:-For information.

1. Director of Education (GNCT of Delhi), Old Secretariat, New Delhi-110054.