

292

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 676

Dated: 22/12/2021

To,  
The Principal,  
Govt. Co-Ed Sarvodaya Vidyalaya,  
Sector-04 (Extn.), Rohini,  
Delhi-85.

**Sub:** Issue of FSC in r/o Govt. Co-Ed Sarvodaya Vidyalaya, Sector-04 (Extn.), Rohini, Delhi-85.

Sir,


Kindly reference to online e-mail dated 22.11.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 10.12.2021, in presence of **Dr. Rajeev Kumar (Head of School)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 450 LPM found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

  
(Dhrampal Bhardwaj)  
Dy. Chief Fire Officer  
Tel:-01123414250

etc  
21/12/2021