

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001** C 4

No. F6/DFS/MS/School/WZ/2021/ 667

Dated: 22/12/2021

To,

Asst.Engineer,(E)  
Edu. Sub-Divn M1-1, (N)  
PWD, ITI Campus, Pusa,  
New Delhi-110012.

**Subject:-** Regarding Issuance of Fire Safety Certificate in r/o M/s Govt. Boys Senior Secondary School No.1, Punjabi Bagh, New Delhi - 110026 (School ID-1515010)

Sir,

This is in reference to your letter No. 54 (SPS School)/PWD Edu. Sub-Divn M1-1 (N) 2021-22/133 dated 10/09/2021, on the subject cited above. In this connection, it is to inform you that the School Building was inspected by the officer concerned of this department on 03/12/2021 in the presence of Sh. Sanjay Chauchan to check the workability of fire safety arrangements provided in the building.

During Inspection it has been observed that the School building building is comprised of Ground + 03 upper floors served by 03 staircases. Fire safety arrangements Such as First – Aid Hose reels, Over head water storage tank, Exit Signage's are provided. However the following Shortcomings were observed.

1. First-Aid Hose Reels are provided but not functional.
2. Terrace fire pump of capacity 900 LPM is provided but not functional & not on automode.
3. Over head water Storage tank capacity of 10,000 ltrs is provided but found empty.
4. Exit signages are not provided.
5. Class room doors opening outward on the corridor create hindrance for evacuation.

In view of the above Shortcomings, the application for Issuance for Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall is at the risk and liabilities of the Owner/Occupier.

Yours Faithfully

(Atul Garg)

Director

Delhi Fire service

Copy To: -

1. The Principal, M/s Govt. Boys Senior Secondary School No.1, Punjabi Bagh, New Delhi - 110026 (School ID-1515010).
2. The Directorate of Education old Secretariat, Delhi-110054.

o/c  
20/12/2021