

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/NDZ/ 07

Dated: 07/01/2022

To,

The Administrator,  
City Convent Sec. School,  
C-19, New Modern,  
Shahdara, Delhi-110032

Subject:- Renewal of Fire (NOC).


Sir,

With reference to your letter dated 29/11/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. Aman Choudhary, Administrator on dated 13/12/2021. The school building comprises of ground plus two upper floors (Two blocks A & B). During the course of inspection following observations were made:-

1. One staircase of width 1.50 meter failing which an additional staircase of 0.75 meter width is required in block 'B' upto ground plus two upper floors.
2. Fire pumps found removed.
3. Overhead water tank found removed.
4. Hose reels containing 30m of length and 20mm bore terminating in to a shut-off nozzle of 5mm outlet connected to the pump shall be provided for every 1000sqm. of covered area subject to a minimum of one hose reel on each block at per floor of the school building along with fire pump & OHT, are required to be provided.
5. Exit signages are required to be provided at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully,

  
6/1/22

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer



Copy to:-

The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi-110053