

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2021/06

Dated: - 07/01/2022



To.

The Principal,
G.D. Goenka Public School, E- 1/14,
East Patel Nagar, New Delhi- 110008.

Sub.- Regarding issued of Fire Safety Certificate in r/o G.D. Goenka Public School, E- 1/14, East Patel Nagar, New Delhi- 110008.

Sir,

Please refer to your email Id anupkhanna974@gmail.com dated 06.12.2021, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Smt. Meeta Dhawan, Principal of the School on 17.12.2021 to check the functionability of the existing fire safety arrangements in the school building.

During the inspection, it has been observed that the said school building having two blocks, First block is comprised of lower ground, Upper ground plus two upper floors and Second block is comprised of basement, ground plus two upper floors and teen shade on terrace, said school building served by two nos. of staircases from ground to upper floors having width 1.20 & 0.90 mts and one staircases from basement floor to ground floor having width 0.65 mts. Fire safety arrangements such as hose reel, fire extinguishers, D.G. Set etc. found provided in the school building. However, the following shortcomings were observed:-

1. One staircase found in basement against requirement of two staircases.
2. Found two staircase having width 1.20 & 0.90 mts. against requirement of two staircase width of 1.50 mts each.
3. Door size found 0.88 mts against required width of 1.20 mts.
4. Hose Reel is provided but not functional.
5. MOFEA found not provided.
6. P.A system found not provided.
7. Automatic Sprinkler system found not provided in basement
8. Terrace pump capacity 450 LPM (one only) is provided against required 450 LPM (02 Nos.)
9. Overhead water storage tank capacity 3,000 ltrs is provided instead of required capacity of 15,000 ltrs.
10. Exit singes found not provided at some places.

In view of the above shortcomings, 'Fire Safety Certificate' cannot be issued at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

for information please.