

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/School/2021/ 08

Dated: 10/01/2022

To

The Principal,
Junior Model School,
C-13, Suraj Park,
Badli, Delhi-110042.

Sub: Renewal of Fire Safety Certificate in r/o Junior Model School located at C-13, Suraj Park, Badli, Delhi-110042.

Kindly reference to online mail dated 08.09.2021, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 549 dated 07.10.2021 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 07.10.2021 for further consideration in this matter.

Yours Faithfully



(Sunil Choudhary)
Dy.Chief Fire Officer

or
my

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/ 549

Dated: 07/10/2021

To,

The Principal,
Junior Model School,
C-13, Suraj Park,
Badli, Delhi-110042.

Sub: Renewal of Fire Safety Certificate in r/o Junior Model School located at C-13, Suraj Park, Badli, Delhi-110042.

Sir,

This is in reference to online e-mail dated 25.02.2021, on the subject cited above. The premise was inspected by the concern nominated authority of this department on **01.09.2021**, in presence of **Smt. Meena Kumari (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of Staircase is 1.10 & 0.95 mtr against the required width of 1.50 mtr.
2. Width of Corridor is 1.2 mtr against the required width of 1.5 mtr.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000

oll
my