

E 7

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/School/2022/SZ/ 12

Dated 14/01/2022

To,

The Principal,
Radiant Model School, 269 A,
Jail Road, Nangal Raya, New Delhi-110046.

Sub: - Regarding grant of NOC from fire safety point of view in r/o M/s Radiant Model School, 269 A, Jail Road, Nangal Raya, New Delhi-110046.



Sir,

Please refer to your letter no. RMS 669 Dated 24/12/2021 the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Raghvender Singh (Manager) was present and it was observed that the building is comprised of ground plus three upper floors and have following shortcomings:-

1. An additional staircase shall be provided 1.5 wide.
2. First aid hose reel not provided.
3. Fire Pump having 450 LPM output 40 M head not provided at terrace.
4. Over head water tank 10, 000 liters not provided.
5. Exits signage's are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service


Copy to:-

Director of Education,
GNCT of NCT of Delhi,
Old Secretariat, New Delhi-54.
(with a request to take further action as school does not have fire NOC)