

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2022/SZ/ 15
To

Dated: 18/01/2022

The Joint Commissioner of Police,
Lic (Branch) 1st Floor, P. S Defence Colony,
New Delhi 110049.

Sub: Regarding grant of Fire Safety Certificate in r/o M/s Barista Coffee (A Unit of Barista Coffee Company Limited) at C-5, Ground Floor, SDA Community Center, Safdarjung Development Area, New Delhi 110016.

Sir,

This is in reference to MHA Portal ID No 2021120828107 dated 09/12/2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 01/01/2022 in the presence of Mr. Yashpal to verify the compliance of the shortcoming issued by this department vide letter even no 6068 dated 11/10/2019. However the status of shortcoming observed is as below.

1. There are two doors having width of 1.53 mtr & 0.93 mtr against the required width of 1.50 mtr each.
2. The Internal Hydrant not provided.
3. Overhead tank capacity 5,000 ltrs provided against the requirement of 20,000 ltrs.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully,


(ATUL GARG)
DIRECTOR /DFS

Copy to: -

1. M/s Barista Coffee (A Unit of Barista Coffee Company Limited) at C-5, Ground Floor, SDA Community Center, Safdarjung Development Area, New Delhi 110016.
2. The Dy. Health Officer, Public Health Department, South MCD, Green Park Zone, New Delhi 110016 (Ref. MHA Portal ID No 2021120828107 dated 09/12/2021)