



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

261

No. F6/DFS/MS/EH/2022/WZ/14  
 To,

Dated: 18/01/2022

The Joint Commissioner of Police (Lic),  
 1<sup>st</sup> Floor, Licensing Unit,  
 Police Station, Defence Colony,  
 New Delhi.

**Subject: - Issuance of Fire Safety Certificate in r/o M/s. Bellagio Restaurant 13,14, Community Centre, Ashok Vihar Phase-II, Delhi-110052.**

Sir,

Please refer to online application no. 2021121928894 dated 22.12.2021 on the subject cited above. In this connection it is to inform you that aforesaid building/premises is comprised of Basement + Ground, Mezzanine + 03 Upper Floors (NOC Applied for Ground, Mazarine & 1<sup>st</sup> floor) have been inspected by the officer concerned of this department on 10.01.2021 in the presence of Sh. Vikas Gupta (Manager) to check the Fire Safety Measures provided in the building as per UBBL & NBC Part-IV.

**During inspection, the following shortcomings have been observed:-**

1. Basement floor is not compartmentalized/segreated at ground floor providing Fire Check Door.
2. Width of staircases is 1.5 m & 1m against requirement of 1.5 m each.
3. Width of Exit Doors is 1.50 m & 1m against requirement of 1.5 m each.
4. Smoke Management System is not provided.
5. 02 nos. CO<sub>2</sub> & ABC type fire Extinguishers are not provided at each floor.
6. First Aid Hose reel is provided at each floor but found nonfunctional.
7. MOEFA is provided but found nonfunctional.
8. Hydrant is provided at each floor but found nonfunctional.
9. Fire Pump at terrace is provided but not on auto operation.
10. Exit Signages are not provided.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Anil Gang)  
 Director

Copy to:-

1. Sh. Gurpdip Singh, M/s. Bellagio Restaurant 13,14, Community Centre, Ashok Vihar Phase-II, Delhi-110052.
2. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.