

C-5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

1 F6/DFS/MS/SZ/2022/ School/18

Dated: 18 /01/2022

To

Dr. Kuldeep Sharma (Manager) <navgiandeepschool@rediffmail.com>
Nav Gian Deep Sr. Sec. Public School,
A - 1/66, Vijay Enclave,
New Delhi - 110045.

Subject: Issuance of Fire Safety Certificate in r/o Nav Gian Deep Sr. Sec. Public School
Located at A - 1/66, Vijay Enclave, New Delhi - 110045.

Sir,

Please refer to Email dated 09-12-2021 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 23/12/2021.

During course of inspection the following shortcomings were observed:

1. The premise is not accessible to fire tender.
2. Two continuous staircases of 1.5m width for all the floors are not provided.
3. Corridor/ passage lead to stair must not be less than 1.5m.
4. One class room door for the class room having less than 45 students & two class room door for the class room having more than 45 students of 1.2m width are not provided.
5. P A system found not provided.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Gang)
Director
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi - 110054