

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

G-28

No. F6/DFS/MS/School/WZ/2022/ 20

Dated: 19 / 01 /2022

To,

Sh. Shashank Sahu,
Assistant Engineer (E), PWD Sub Division 2,
Edu. Elect. Edn. 1 Div. (N), Sector 16, Rohini,
Delhi-110089.

Sub. :-Issuance of Fire Safety Certificate in r/o (New Block) Govt. Sarvodaya Kanya Vidyalaya No. 2 (School ID- 1411030) Located at Shakurpur, Delhi-110034.

Sir,


This has reference to your email dated 27.12.2021 on the subject cited above. In this connection it is to inform you that the above said School building was re-inspected by the officer concerned of this department from safety point of view on 07.01.2022 in presence of Sh. Raju Dass (Supervisor) to see compliance of the shortcomings issued vide letter no. F6 DFS/MS/School/WZ/2021/1649 dated 13.12.2021.

During the course of inspection it has been observed that the Management has rectified some of the shortcomings the status is under:-

S. no.	Shortcomings	Status
1.	The New Building Block is not accessible for fire tenders as 06 m wide motor able road is not provided	Not Rectified
2.	The Main entrance gate is 385 cm wide against requirement of 4.5 m	Not Rectified
3.	Fire Pump is provided but not in auto operation.	Rectified

You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements at your own risk and responsibility. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, Old Secretariat Delhi – 110054.
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya No. 2, Shakurpur, Delhi-110034.