

C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/EH/2022/WZ/ 18

Dated: 18 / 01 / 2022

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit,
Police Station, Defence Colony,
New Delhi,

Subject: - Issuance of Fire Safety Certificate in r/o M/s. Lala Shiv Nath Rai Sumer Chand Confectionary Pvt. Ltd. Located at Shop No. 5, Ground Floor, Vaishali Main Road 41, Pitampura, Delhi-110034.

Sir,

Please refer to online application no. 2021122329172 dated 23.12.2021 on the subject cited above. In this connection it is to inform you that the said building have been re-inspected by the officer concerned of this department on 06.01.2021 in presence of Sh. Satbir Singh (Supervisor) to check compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/EH/2021/WZ/531 dated 22.11.2021 (copy enclosed).

During inspection, it have been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Anil Garg)
Director

Copy to:-

1. Sh. Narender Kumar Jain, M/s. Lala Shiv Nath Rai Sumer Chand Confectionry Pvt. Ltd. Located at Shop No. 5, Ground Floor, Vaishali Main Road 41, Pitampura, Delhi-110034.
2. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.

↗

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/EH/2021/WZ/ 531

Dated: 22 / 11 / 2021

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit,
Police Station, Defence Colony,
New Delhi,

Subject: - Issuance of Fire Safety Certificate in r/o M/s. Lala Shiv Nath Rai Sumer Chand Confectionary Pvt. Ltd. Located at Shop No. 5, Ground Floor, Vaishali Main Road 41, Pitampura, Delhi-110034.

Sir,


Please refer to online application no. 2021091521531 dated 16.09.2021 on the subject cited above. In this connection it is to inform you that aforesaid establishment (Confectionary) in a building comprised of Basement + Ground + 03 Upper Floors & Covered Terrace, has been inspected by the officer concerned of this department on 18.10.2021 in the presence of Sh. Ashish Aggarwal (Manager) to check the Fire Safety Measures provided in the building.

During inspection, the following shortcomings have been observed:-

1. Basement floor is not compartmentalized/segregated providing Fire Check Door.
2. The Width of Exits is 166 cm & 90 cm instead requirements of 1.5 m each.
3. Smoke Management System is not provided.
4. Fire Extinguishers are not provided.
5. Down comer System along with First Aid Hose Reel with 30 m long pipe having 20 mm dia with Shut off nozzle & Hydrant with hose and hose box & Branch is not provided.
6. MOEFA is not provided.
7. Fire Pump at 450 lpm capacity at Terrace is not provided.
8. Over head tank 20,000 ltrs. capacity exclusive for firefighting is not provided.
9. Exit Signages are not provided.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Copy to:-

1. Sh. Madhu Gupta, M/s. Lala Shiv Nath Rai Sumer Chand Confectionry Pvt. Ltd. Located at Shop No. 5, Ground Floor, Vaishali Main Road 41, Pitampura, Delhi-110034.
2. The DHO, Health Deptt. North DMC, Kanjhaola, New Delhi.