

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

C 31

No. F6/DFS/MS/SZ/2022/ School/16

Dated: 18/01/2022

To,

The Principal <paramount23@gmail.com>  
Paramount International School,  
Sector 23, Dwarka,  
New Delhi – 110075.

Subject: Issuance of Fire Safety Certificate in r/o Paramount International School Located at Sector 23, Dwarka, New Delhi – 110075.

Sir,

Please refer to Email Dated 15/12/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 28-12-2021 for fire safety point of view.

During the course of inspection the following shortcomings are noticed.

1. Six meter wide internal road around the building found not provided.
2. The width of staircases is less than 1.5m.
3. All the newly constructed class Rooms must have one exit of 1.2 M or two exit of 1.2M if number of students is more than 45.
4. Fire Check Doors are found not provided as per plan.
5. Pressurization system found not provided for lift shaft & staircases.
6. Fire extinguishers are not found provided at 4<sup>th</sup> floor as shown in plan.
7. Hose Reel Hoses & hydrants found nonfunctional at Ground, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floors.
8. The fire fighting systems are not extended to 4<sup>th</sup> floor.
9. Manual call point found not provided.
10. The terrace pump of 900 LPM found nonfunctional.
11. Dimension of the terrace tank exclusively for fire fighting not provided.
12. Exit signage found not provided
13. Communication system in lift car & fireman ground switch & Lift signage are not provided
14. Fire control room equipped with Flow Switch Panel, PA System Panel, Battery backup & Building Floor Plans must be provided at ground level.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service.

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054