

C19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2021/ 22

Dated: 19 /01/2022

To

The Principal,
EDMC Primary School,
Block-7, Trilok Puri
Delhi-91.

**Sub: Regarding grant of FSC in r/o EDMC Primary School at Block-7, Trilok Puri
Delhi-91.**



Sir,

This has reference to your email dated 25/10/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 04/01/2022 in the presence of Mr. Kuldeep (MCD) and observed that following shortcoming was observed :-

1. Hose reel provided but not functional.
2. Fire pump provided but not functional.

Hence, Fire Safety Certificate can not be considered at this stage.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service


Copy to:-

The Director of Education,
EDMC, Udyog Sadan,
Plot No. 419, FIE, Patparganj, Delhi-92.