

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2022/NDZ/ 23

Dated 20/01/2022

To,

The Manager,
EDMC Primary School
B-2, Nand Nagri,
Delhi-110094

Sub:- Regarding Issuance Fire Safety Certificate in EDMC Primary School B-2, Nand Nagri
Delhi-110094.

Sir,

With reference to your letter No. nil dated 27/12/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 05/01/22 in presence of Mrs Shahiba Parveen, Principal of the School. The following points / shortcomings were noticed in the building comprised of ground plus three upper floors (two separate blocks).

1. Over head tank 3,000 ltrs provided in place of 10,000 liter in as required.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92