



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/EH/2022/NDZ / 29

Dated: 25/1/22

To,
The Joint Commissioner. (Licensing)
Office of the Joint Commissioner of Police (Lic.)
1st floor, Police Station Defence Colony
New Delhi

Subject :-Regarding issuance of Fire Safety Certificate in M/s Jubilant Food works ltd.(Domino's Pizza), S.no- C-4/73 A-Block GF, Yamuna Vihar, main Wazirabad Road, Delhi-110053

Sir,

With reference to your online application No. 2021111026056 dated 11/11/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned restaurant from fire safety point of view in presence of Mr. Rajesh (Shift Manager). During the course of inspection the following shortcomings were observed.

1. Exit door of 2 mtr & 1.50 mtr wide is not provided.
2. First Aid Hose reel is not provided.
3. MOEFA is not provided.
4. Down-comer is not provided.
5. A fire pump having 450 lpm output of 40 meters head at terrace is not provided.
6. Over head tank 20,000 liters not provided.
7. Standby supply not provided.
8. Site plan showing such as abutting road, access to building, etc is not submitted as per UBBL-2016.
9. Width of staircase & exit door going to upside is not mentioned on the plans as per NBC part-4/UBBL-2016
10. Basement covered area is proposed whereas plan is not submitted.
11. Proof of year of construction is not submitted.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

**Director
Delhi Fire Service**

Copy to:-

1. The Manager
M/s Jubilant Foodworks Ltd. (Domino's Pizza)
Shop no.-C-4/73 , A-Block Yamuna Vihar,
Wazirabad road, Delhi-110053
MHA ID. 2021111026056
2. The Commissioner (EDMC)
Plot No 419, Patparganj Industrial Area, Delhi-110092