

65

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/WZ/2022/ 30

Dated: 25/11/22

To

The Joint Commissioner of Police (Licensing Unit),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
Defence Colony, New Delhi.

Sub: - Regarding inspection report in r/o M/s. Leeway Bar and Restaurant located at Upper Ground Floor, RR-09, Mianwali Nagar, New Delhi- 110087.

Sir,

This is in reference to the online application received vide ID-2021102224874 through online MHA portal regarding issuance of fire safety certificate in respect of M/s. Leeway Bar and Restaurant located at RR-09, Mianwali Nagar, New Delhi- 110087. The aforesaid eating house was inspected by the officer concerned of this department on 07.01.2022 in presence of Sh. Shanky Garg (owner), to check the provisioning of the fire safety arrangements provided in the building.

During the course of inspection, it was observed that the said eating house is running at Upper Ground Floor of M/s. Leeway Residency guest house comprised of Basement, stilt, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, hose reel, fire pump etc. found provided. However, following shortcomings were observed: -

1. Overhead water tank capacity 20,000 lts is not provided.
2. MOEFA is not provided.
3. Service shaft opening are not sealed at each floor.
4. Width of exit door is 1.30 mts against required with of 1.50 mts.
5. Exit signages are not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority /statutory authority is requested that premises should not be allowed to run till it provide all necessary fire safety arrangements.

Yours faithfully

  
(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. Sh. Shanky Garg, M/s. Leeway Bar and Restaurant, Upper Ground Floor, RR-09, Mianwali Nagar, New Delhi- 110087.